

October 11, 2022

Liz Burdick Planning Director Town of Montville 310 Norwich-New London Turnpike Uncasville, CT 06382

Re: Cornerstone Ventures LLC - Gay Hill Road Resubdivision, revised 9/24/22

Dear Ms. Burdick:

I have reviewed the revised plans for the above 29-Lot resubdivision and have the following comments:

- 1. An individual site plan must be submitted for each lot at the time of development.
- 2. The footing drain outlet on lot 13 is less than the required 25 feet from the well.
- 3. The sewer line on lot 26 is less than the required 25 feet from the well.
- 4. The wells on lots 21, 22 and 27 must be a minimum of 75 feet from a below grade sewage pump and chamber, either internal or external. The sewage pumps must be included on the individual site plans.

Sincerely,

Michael J. Kirby, R.S.

Chief Environmental Sanitarian