

From: [jon lilly](#)
To: [Liz Burdick](#); [Kevin Loiler](#); [Jon Lilly](#)
Subject: 2040 Route 32
Date: Wednesday, June 14, 2023 7:08:23 AM
Attachments: [2040 Rt 32.png](#)

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good morning Liz,

As discussed on the phone yesterday the proposed gas station 2040 Rt 32 has the water and sewer crossing Rt 32 there are a lot of utilities in this area that they would have to cross we would rather see the utility connections made off of Podurgiel Ln. Also, the retention pond location is right on top of our water and sewer mains. Need to find a new location for pond. Attached is a GIS photo showing rough location of our mains.

Thanks Jon

Jon Lilly
Chief Water operator
Senior Maintenance & Operations Inspector
Town of Montville WPCA
83 Pink Row
Uncasville Ct. 06382
860-949-5996 (C)
lillymtvwpcf@sbcglobal.net