

## LETTER OF TRANSMITTAL

### **Town of Montville Planning Department**

Date: 6/22/2023

(860) 848-6779

Email: [sradford@montville-ct.org](mailto:sradford@montville-ct.org)

To: Fire Marshal

**Project Name: 23 SP 7 – Industrial Site Development**

**Project Location: 69 Fitch Hill Road, Uncasville, CT**

The following documents were submitted for your review:

- A-101 Floor Plan (80 x 248), Floor Plan, Steel building 60 x 100, and A-103 Elevations 80 x 248

Notes: N/A

All documents are provided digitally. If you require a hard copy to review and/or additional information, please contact the office. Please refer to the application for contact information.

All comments shall be submitted via email or hard copy to the Planning Department at [sradford@montville-ct.org](mailto:sradford@montville-ct.org).

**Project Name: 23 SP 7 – Industrial Site Development**

**Project Location: 69 Fitch Hill Road, Uncasville, CT**

Reviewing Agency: Fire Marshal

Review Date: 6/22/23

Reviewed By: Paul D. Barnes

Comments: All dwelling units require a full sprinkler system and fire alarm.

Information required as to what the other buildings be utilized/classified as. Also, due to square footage, those buildings may require a full sprinkler system and fire alarm.