## **Stacy Radford**

From: Michael Kirby <chfsanit@uncashd.org>

**Sent:** Tuesday, July 25, 2023 2:05 PM

**To:** Stacy Radford

Cc: Liz Burdick; Alyssa Brochu; Ellen Bartlett (ebartlett@claengineers.com)

**Subject:** 69 Fitch Hill Road

**CAUTION:** This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Based on the plan revised 7/20/23 I have the following comments:

- 1. The property meets the minimum requirements of the Public Health Code for subsurface sewage disposal. Additional testing will be required prior to the issuance of building or septic permits.
- 2. Detailed floor plans and descriptions of the uses of the building must be submitted to the District prior to the issuance of any permits.
- 3. Floor drains may not be installed unless a permit is first obtained from CT DEEP.
- 4. Individual water meters should be installed in each building.

Michael J. Kirby, R.S.

Chief Environmental Sanitarian 860-823-1189 Extension 119

