

Stacy Radford

From: Michael Kirby <chfsanit@uncashd.org>
Sent: Wednesday, August 2, 2023 3:16 PM
To: Stacy Radford
Cc: Liz Burdick; Casey Burch
Subject: RE: 23 SUB 1 - 958 Route 163, Oakdale, CT

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

1. Both lots meet the requirements of the CT Public Health Code for subsurface sewage disposal.
2. Clarify if the Reserve System Design is for both lots or only the new system on Lot 2. If only for lot 2, a design for lot 1 must be included.
3. MLSS is applicable on Lot 1 and the calculations must be included.

From: Stacy Radford <sradford@montville-ct.org>
Sent: Monday, July 31, 2023 12:10 PM
To: Michael Kirby <chfsanit@uncashd.org>
Cc: Liz Burdick <lburdick@montville-ct.org>; Meredith Badalucca <mbadalucca@montville-ct.org>
Subject: 23 SUB 1 - 958 Route 163, Oakdale, CT

Good Morning:

Please review the Application number 23 SUB 1 for the above mentioned property using the link below. Please forward your comments to my attention.

<https://link.edgepilot.com/s/071d2411/2WnUEEJJV0uNcAhLjPIICA?u=https://www.townofmontville.org/form-repository/23-sub-1/>

Please feel free to contact our office if you have any questions.

Thank You!

Stacy Radford

Administrative Assistant – Dept. of Land Use & Development
Town of Montville
310 Norwich-New London Tpke., Uncasville, CT 06382
Telephone: (860) 848-6779

Links contained in this email have been replaced. If you click on a link in the email above, the link will be analyzed for known threats. If a known threat is found, you will not be able to proceed to the destination. If suspicious content is detected, you will see a warning.