

# CLA Engineers, Inc.

Civil • Structural • Survey

317 MAIN STREET

NORWICH, CT 06360

(860) 886-1966

(860) 886-9165 FAX

October 26, 2023

Ms. Liz Burdick  
Town Planner  
310 Norwich-New London Tpk.  
Uncasville, CT 06382

RE: Gateway Terminal – Dredge Material Processing  
CLA-7387P

Dear Liz:

We have reviewed the revised plans dated Oct. 10, 2023 and supporting documents for the proposed processing of dredged material at the Gateway Terminal. We have the following comments:

1. The proposed location for storage of dry material is too small to contain anything near 10,000 CY.
2. The E&S Controls must show protection of the storm drainage inlet near receiving Bin. 1
3. A detail of the secondary spill containment must be added to the plans
4. Given the conditions on the site being next to the river and the proposed operation of transporting, treating and storing dredged material, a substantial E&S Bond amount seems appropriate including the waddles, secondary spill containment, anti-tracking installation and a 100% contingency.
5. The temporary docking improvements for the barges must be detailed on the plans.

Very truly yours,



Thomas L. Cummings, P.E

TLC:bab