CLA Engineers, Inc.

Civil • Structural • Survey

317 MAIN STREET

NORWICH, CT 06360

(860) 886-1966

(860) 886-9165 FAX

March 6, 2024

Mr. Matthew Davis Town Planner 310 Norwich-New London Tpke, Uncasville, CT 06382

RE:

Morosky Subdivision 581 Oakdale Road

CLA-7387Z

Dear Matt:

We have reviewed the plans and supporting documents submitted for the Morosky Subdivision on Rt. 163. We have the following comments:

- 1. Clearing limits must be shown.
- 2. The silt fencing must be shown extending along the clearing limits on the northerly side of the lot.
- 3. An evaluation of the effect of the subdivision on drainage in the area must be provided.
- 4. An E&S bond estimate must be submitted for review.

Very truly yours,

Thomas L. Cummings, P.E.

TLC:bab

cc: Meredith Badalucca