

CLA Engineers, Inc.

Civil • Structural • Survey

317 MAIN STREET

• NORWICH, CT 06360

• (860) 886-1966

• (860) 886-9165 FAX

September 10, 2024

Stacy Radford
Zoning & Wetland Officer – Dept. of Land Use & Development
Town of Montville
310 Norwich-New London Tpke., Uncasville, CT 06382
Via Email: sradford@montville-ct.org

RE: Inland Wetland Application 24 IWC 7
339 Chesterfield Road Site Development
CLA-7873

Stacy,

The Engineer has provided supplemental calculation and support data indicating the culvert crossing has capacity to convey the 100-year storm. The Engineer has taken a conservative approach regarding time of concentration. We agree that the culvert crossing will have adequate capacity to convey this storm event.

The Engineer has addressed all previous comments.

Thank you for the opportunity to provide this review. Please feel free to call us at our office or email khaubert@claengineers.com or brusso@claengineers.com with any questions or comments.

Very truly yours,
CLA Engineers, Inc.



Kyle Haubert, P.E.



Robert Russo C.S.S.