

**From:** [Alyssa Brochu](#)  
**To:** [Meredith Badalucca](#)  
**Cc:** [Stacy Radford](#); [Sherry Pollard](#)  
**Subject:** Re: 25 SITE 5 - 375 Maple Avenue  
**Date:** Tuesday, June 24, 2025 12:47:18 PM  
**Attachments:** [Outlook-UHD\\_2Color](#)

---

**CAUTION:** This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Meredith,

Thank you for the information. My only comment about the wells would be that the one they are getting rid of would need to be properly abandoned and permitted by a licensed well driller.

And then once they clarify what the second well would be used for I can see if I have any further comments.

Also, thank you so, so much for the fans yesterday! They really saved us.

~Alyssa

Alyssa Brochu, REHS/RS  
Registered Environmental Health Specialist  
401 West Thames Street, Suite 106  
Norwich, CT 06360  
Phone: (860) 823-1189 ext. 120  
Fax: (860) 887-7898



---

**From:** Meredith Badalucca <[mbadalucca@montville-ct.org](mailto:mbadalucca@montville-ct.org)>  
**Sent:** Friday, June 20, 2025 9:37 AM  
**To:** Alyssa Brochu <[abrochu@uncashd.org](mailto:abrochu@uncashd.org)>  
**Cc:** Stacy Radford <[sradford@montville-ct.org](mailto:sradford@montville-ct.org)>; Sherry Pollard <[spollard@montville-ct.org](mailto:spollard@montville-ct.org)>  
**Subject:** FW: 25 SITE 5 - 375 Maple Avenue

Good morning Alyssa,

I didn't include you on the original email as they are not proposing any wells or septic. However, I noticed while completing my review that there are 2 wells on site. One is indicated that it will be removed. The other I have as a technical review comment asking if it is intended to be removed.

Please forward any comments you may have to myself, Stacy and Sherry. Thank you.

Regards,

***Meredith Badalucca, CZEO***

Assistant Planner  
Town of Montville  
310 Norwich New London Turnpike  
Uncasville, CT 06382  
860-848-6779

---

**From:** Meredith Badalucca

**Sent:** Thursday, June 12, 2025 12:46 PM

**To:** Douglas Colter <dcolter@secogct.gov>; Doug Colter <dcolter@montville-ct.org>; Paul Barnes <pbarnes@montville-ct.org>; John Meigel <JMeigel@montville-ct.org>; John Carlson <JCarlson@montville-ct.org>; Derek Albertson <dalbertson@montville-ct.org>; Ronald K. McDaniel <rmcdaniel@montville-ct.org>; LT David Radford <Dradford@montvillepolice.org>; Chief Wilfred Blanchette <wblanchette@montvillepolice.org>; John Carlson <JCarlson@montville-ct.org>; David McKay <dmckay@boundariesllc.net>

**Cc:** Stacy Radford <sradford@montville-ct.org>; John Faulise <jfaulise@boundariesllc.net>

**Subject:** 25 SITE 5 - 375 Maple Avenue

Good afternoon,

Below please see the link below for application materials for a proposed industrial trailer storage facility along with relocation of town drainage.

<https://link.edgepilot.com/s/3959bc2b/r-EYHVxXK06y2ObllOTunQ?u=https://www.townofmontville.org/form-repository/25-site-5-375-maple-avenue-industrial-trailer-storage-facility/>

Please provide any comments to myself and Stacy. Thank you.

Regards,

***Meredith Badalucca, CZEO***

Assistant Planner  
Town of Montville  
310 Norwich New London Turnpike  
Uncasville, CT 06382  
860-848-6779

Links contained in this email have been replaced. If you click on a link in the email above, the link will be analyzed for known threats. If a known threat is found, you will not be able to proceed to the destination. If suspicious content is detected, you will see a warning.