

CLA Engineers, Inc.

Civil • Structural • Survey

317 MAIN STREET • NORWICH, CT 06360 • (860) 886-1966 • (860) 886-9165 FAX

August 20, 2025

Stacy Radford, WEO
Town of Montville
310 Norwich-New London Tpke., Uncasville, CT 06382
Via Email: sradford@montville-ct.org

RE: Site Plan Application review
47 Sharp Hill Road Subdivision
CLA-7873N

Dear Stacy:

CLA Engineers, Inc. (CLA) has received and reviewed the revised application materials for the above referenced project including :

- A 17-sheet plan set prepared by H and H engineering and Boundaries LLC, dated 7/10/25
- A soil scientists' letter prepared by Ian Cole CSS dated September 12, 2024
- A Stormwater Management Report prepared by H and H dated 7/10/25

CLA has performed a review of the revised application documents and find all of our comments have been adequately addressed except for one:

Plans

- Narrative
 - List other possible permits (state, local, federal) that may be needed. This is part of the 2024 CDEEP E&S Manual Check List. If no other permits are needed for the project, it should be stated on the project plans.

Thank you for the opportunity to provide this review. Please feel free to call me at our office or email brusso@claengineers.com with any questions.

Very truly yours,
CLA Engineers, Inc.

Robert C Russo

Robert C. Russo CSS.