

Sherry Pollard

From: Alyssa Brochu <abrochu@uncashd.org>
Sent: Friday, August 22, 2025 11:49 AM
To: Sherry Pollard
Cc: Meredith Badalucca; Stacy Radford
Subject: Re: 25 SUB 5 - 158 Fitch Hill Rd. 3-Lot Subdivision
Attachments: Outlook-UHD_2Color

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Sherry,

The septic system reserve area for lot 37 must be H20 rated as it is located partially under the driveway.

Thank you,
Alyssa

Alyssa Brochu, REHS/RS
Registered Environmental Health Specialist
401 West Thames Street, Suite 106
Norwich, CT 06360
Phone: (860) 823-1189 ext. 120
Fax: (860) 887-7898



From: Sherry Pollard <spollard@montville-ct.org>
Sent: Wednesday, August 20, 2025 11:46 AM
To: khaubert@claengineers.com <khaubert@claengineers.com>; Douglas Colter <dcolter@secogct.gov>; Doug Colter <dcolter@montville-ct.org>; John Meigel <JMeigel@montville-ct.org>; John Carlson <JCarlson@montville-ct.org>; Alyssa Brochu <abrochu@uncashd.org>; LT David Radford <Dradford@montvillepolice.org>; Chief Wilfred Blanchette <wblanchette@montvillepolice.org>; Kristy Kupec <kkupec@montville-ct.org>; Carlos Peixoto <cpeixoto@montville-ct.org>
Cc: Meredith Badalucca <mbadalucca@montville-ct.org>; Stacy Radford <sradford@montville-ct.org>
Subject: 25 SUB 5 - 158 Fitch Hill Rd. 3-Lot Subdivision

Good Morning,

Attached hereto, you will find a **Revised Site Plan** dated 8/19/25.

This application will be on the August 26th PZC agenda. Please provide comments to Meredith & and myself in a time frame to allow the applicant to address all comments and allow for a second review by all departments.

Kristy and Carlos, this is an FYI for your department. However, should you have any comments, please provide them.

Thank You

Sherry Pollard

Administrative Assistant – Department of Land Use

Town of Montville

310 Norwich-New London Tpke, Uncasville, CT 06382

Telephone: (860) 848-6779