



Ellen Bartlett, P.E. • CPSWQ, Leed Accredited  
September 12, 2025

Town of Montville  
Inland Wetlands Commission  
ATTN: Douglas K. Brush, Chair  
Montville Town Hall  
310 Norwich-New London Turnpike  
Uncasville, CT 06382

Re: Fluid Line Products LLC  
Industrial Building Development  
179 Gallivan Lane  
Uncasville, CT 06382  
GSD-72

Dear Mr. Brush:

Green Site Design is in receipt of a letter dated September 7, 2025, from the Town's reviewing soil scientist Ian Cole. GSD is providing this letter in response to Mr. Cole's comments on GSD's submittal for the 179 Gallivan Lane Site. GSD's responses are provided below and follow the same numerical sequence as Mr. Cole's comments.

1. No response needed.
2. The plans show that the sediment barrier will be a combination of silt fence and wood chips, so no haybales will be used. This will minimize the risk of importing invasive species. The erosion mat has been changed to North American Green C125BN which is made of natural fibers.
3. The existing tree line and proposed clearing have been clarified on the plans. The E&S now extends around the limits of disturbance.
4. The plans now call for a warm season seed mix in the forebay and New England Erosion Control /Restoration Mix for Detention Basins as requested.
5. The plans now call for 3-4' tall shrubs as requested.

GSD believes that all of Mr. Cole's comments have been properly addressed.

Sincerely,

Robert C. Russo  
Soil Scientist, Green Site Design  
Norwich, CT