

From: [Stacy Radford](#)
To: [Stacy Radford](#)
Subject: FW: GSD-68 - Fitch Hill
Date: Friday, September 12, 2025 12:36:47 PM
Attachments: [GSD 68 - Site Plan Review 9.12.25.pdf](#)
[Basin Comparisons.pdf](#)

From: Ellen Bartlett <ebartlett@greensitedesignllc.com>
Sent: Friday, September 12, 2025 11:44 AM
To: Meredith Badalucca <mbadalucca@montville-ct.org>; Stacy Radford <sradford@montville-ct.org>
Cc: David McKay <dmckay@boundariesllc.net>
Subject: FW: GSD-68 - Fitch Hill

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good morning,

The plans have been revised, specifically the As-built plan, to call out that the forebay from south side of basin 2 must be built, and that the temporary riprap into stormwater basin 2 must be removed once the roadway is completed.

This riprap was installed because until the roadway is completed, stormwater was washing out the basin during large storm events.

Also attached is the basin comparison table and pond reports, showing that the as-built basins are larger than the approved basins were.

We will drop off paper copies of all this this afternoon.

Ellen Bartlett, PE, CPSWQ
LEED Accredited Professional

GREEN SITE DESIGN LLC

317 Main Street
Norwich, CT 06360
Ph: 860-892-1380
www.greensitedesignllc.com

CT MBE/WBE