

## Sherry Pollard

---

**From:** Sherry Pollard  
**Sent:** Friday, September 12, 2025 3:30 PM  
**To:** Sherry Pollard  
**Subject:** FW: 257 Chesterfield Road

**From:** Joe Wren <[jwren@indigo-land.com](mailto:jwren@indigo-land.com)>  
**Sent:** Friday, September 12, 2025 2:02 PM  
**To:** Brian Florek <[bflorek@floreksurveyingllc.com](mailto:bflorek@floreksurveyingllc.com)>  
**Cc:** Meredith Badalucca <[mbadalucca@montville-ct.org](mailto:mbadalucca@montville-ct.org)>; Mike Desautels <[desautels\\_mike@yahoo.com](mailto:desautels_mike@yahoo.com)>; Stacy Radford <[sradford@montville-ct.org](mailto:sradford@montville-ct.org)>  
**Subject:** Re: 257 Chesterfield Road

**CAUTION:** This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Meredith - one note - the drainage report says a 12x14 preformed scour hole but Kyle and I agreed that is way oversized intended more for interstate highway infrastructure so we agreed that an 8x8 preformed scour hole would be more than appropriate for this circumstance.

Thank you!

Joe

*Joe Wren, PE  
Principal  
Indigo Land Design, LLC  
40 Elm Street, 2nd Floor  
Old Saybrook, CT 06475*

*P: 860-388-9343 Ext. 205  
C: 860-202-0693  
E: [jwren@Indigo-Land.com](mailto:jwren@Indigo-Land.com)  
W: [www.Indigo-Land.com](http://www.Indigo-Land.com)*