

From: [Stacy Radford](#)
To: [Stacy Radford](#)
Subject: FW: 25IWC22 - 69 Fitch Hill Rd
Date: Monday, September 15, 2025 8:51:54 AM

From: David McKay <dmckay@boundariesllc.net>
Sent: Saturday, September 13, 2025 1:02 PM
To: Stacy Radford <sradford@montville-ct.org>
Cc: Ellen Bartlett <ebartlett@greensitedesignllc.com>
Subject: RE: 25IWC22 - 69 Fitch Hill Rd

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good afternoon Stacy,

Based on the additional information provided on September 12, the field modifications to the stormwater management system meet the intent of the approved site plans. As noted in Robert Russo's letter, the site was disturbed prior to construction and the additional disturbance within the upland review area will be vegetated and stabilized and should not have a negative effect on the surrounding inland wetlands.

Please let me know if you have any questions or need additional information.

Thank you!
Dave

David C. McKay, P.E.

Boundaries L.L.C.

179 Pachaug River Drive

P.O. Box 184

Griswold, CT 06351

Phone: 860-376-2006

Fax: 860-376-5899

Cell: 860-841-1059