

Julie Boyle

From: Ronald K. McDaniel
Sent: Friday, December 5, 2025 6:38 AM
To: Julie Boyle
Cc: Derek Albertson
Subject: Fw: Redevelopment of 2227 Route 32/Follow up review
Attachments: 2227 rt32 water service.jpg

The proposed 1" domestic service should be eliminated along with the others that currently exist. See attached. The domestic service should branch off the proposed fire line close to the new building with isolation valves for each.

*Ronald McDaniel
WPCA Administrator
83 Pink Row
Uncasville, CT 06382
860-848-6711*

Water Service Card

Street or MBL Norwich-New London Tpke Main Size & Material 16" Hse No. 2233

Tap — Svc Size & Material 1" Depth UNK. Svc Length UNK. Tied-in Date 11/04/2005

Contractor: Preston Plumbing

