

**From:** [Ronald K. McDaniel](#)  
**To:** [Julie Boyle](#)  
**Subject:** Fw: Redevelopment of 2227 Route 32/Follow up review  
**Date:** Friday, December 5, 2025 7:01:31 AM  
**Attachments:** [2227 rt32 water service.jpg](#)

---

Also, the developer should have another valve at the curb line. That way the service can be shut down without going into road.

*Ronald McDaniel*  
*WPCA Administrator*  
*83 Pink Row*  
*Uncasville, CT 06382*  
*860-848-6711*

---

**From:** Ronald K. McDaniel <rmcdaniel@montville-ct.org>  
**Sent:** Friday, December 5, 2025 6:37 AM  
**To:** Julie Boyle <jboyle@montville-ct.org>  
**Cc:** Derek Albertson <dalbertson@montville-ct.org>  
**Subject:** Fw: Redevelopment of 2227 Route 32/Follow up review

The proposed 1" domestic service should be eliminated along with the others that currently exist. See attached. The domestic service should branch off the proposed fire line close to the new building with isolation valves for each.

*Ronald McDaniel*  
*WPCA Administrator*  
*83 Pink Row*  
*Uncasville, CT 06382*  
*860-848-6711*

---