

Julie Boyle

From: Ronald K. McDaniel
Sent: Tuesday, February 17, 2026 6:16 AM
To: Julie Boyle; John Meigel
Subject: Fw: 245 Route 32

Looks like an old set of plans. Paul Barnes first required a fire hydrant then deleted it as there is one at the road.

Ronald McDaniel
WPCA Administrator
83 Pink Row
Uncasville, CT 06382
860-848-6711

From: Jon Lilly <jlilly@montville-ct.org>
Sent: Tuesday, February 17, 2026 6:13 AM
To: Ronald K. McDaniel <rmcdaniel@montville-ct.org>; Kevin Loiler <kloiler@montville-ct.org>; Derek Albertson <dalbertson@montville-ct.org>
Subject: Re: 245 Route 32

I believe the fire hydrant was deleted on previous versions and it says on the utility drawing note 12 that they are using pumps I think this is also from a old version just want to confirm.

Thanks Jon

Jon Lilly
Chief Water operator
Senior Maintenance & Operations Inspector
Town of Montville WPCA
83 Pink Row
Uncasville Ct. 06382
860-949-5996 (C)
jlilly@montville-ct.org

From: Ronald K. McDaniel <rmcdaniel@montville-ct.org>
Sent: Wednesday, February 11, 2026 2:17 PM
To: Jon Lilly <jlilly@montville-ct.org>; Kevin Loiler <kloiler@montville-ct.org>; Derek Albertson <dalbertson@montville-ct.org>
Subject: 245 Route 32

Please take a new look at his plans and get me any comments.

Ronald McDaniel
WPCA Administrator
83 Pink Row
Uncasville, CT 06382
860-848-6711