

# CLA Engineers, Inc.

Civil • Structural • Survey

317 MAIN STREET • NORWICH, CT 06360 • (860) 886-1966 • (860) 886-9165 FAX

April 17, 2026

Meredith Badalucca, Assistant Planner  
Town of Montville  
310 Norwich-New London Tpke., Uncasville, CT 06382  
Via Email: [mbadalucca@montville-ct.org](mailto:mbadalucca@montville-ct.org)

RE: Site Plan Application 26 SITE 3 Review  
061-002-000 Noble Hill Road  
CLA-7873J

Dear Meredith:

CLA Engineers, Inc. (CLA) has received the application materials for the above referenced project located on the Town Form Repository: <https://www.townofmontville.org/form-repository/26-site-3-061-002-000-noble-hill-road-mitigation-of-unpermitted-removal-of-eart/>

CLA has performed a review of the application documents and offer the following comments:

1. The proposed topsoil thickness should be specified for the disturbed non-wetland soil areas.
2. Temporary erosion control blanket, hydroseed with bonded fiber matrix, or equal should be provided on the finished slopes that are steeper than 3:1.
3. An E&S bond was proposed under the IWC permit and is sufficient for this work.

Thank you for the opportunity to provide this review. Please feel free to call me at our office or email [khaubert@claengineers.com](mailto:khaubert@claengineers.com) with any questions.

Very truly yours,  
**CLA Engineers, Inc.**



Kyle Haubert, P.E.