

ADDENDUM NO. 1

Notice to Bidders for

**Maple Avenue Improvement Project
(Route 163 to DPW Garage)
Bid No. 2026-11**

for
Town of Montville

ADDENDUM ISSUED: July 17, 2026

This Addendum forms part of the Contract Documents and modifies the original Project Manual & Specifications and Drawings dated June 17, 2026. Acknowledge receipt of this Addendum in the Bid Proposal. Failure to do so may subject the Bidder to disqualification.

This Addendum is issued to modify the Contract Documents as follows:

Invitation for Proposals

The second sentence of the second paragraph should read:

A proposal must be delivered by regular mail, overnight mail, or by hand to the Town of Montville, Finance Office, 310 Norwich/New London Turnpike, Uncasville, Connecticut 06382, with the proposal contained in a sealed envelope marked “**Maple Avenue Improvement Project – (Route 163 to DPW Garage)**”.

Questions

1. What are the limits for clearing and grubbing? Are there any specific locations for this work besides where headwalls, drainage structures, and other appurtenances are to be placed?

Response: There are no specific limits for clearing and grubbing. Clearing and grubbing shall be undertaken where deemed necessary to provide sufficient room to install the proposed work e.g. guardrail replacement.

2. Confirm the scope of the Temporary Bituminous Concrete Pavement item is to be one 2" lift of HMA 0.375?

Response: Temporary bituminous concrete shall be used to provide temporary reinstatement to the pavement should it be deemed necessary by the Owner or Engineer. A single 2" lift of HMA 0.375 would be sufficient.

END OF ADDENDUM 1