

From: [Stacy Radford](#)
To: [Stacy Radford](#)
Subject: FW: 26IWC11 - 38 Laurel Point Drive
Date: Tuesday, August 25, 2026 3:26:43 PM

From: Harry Heller <hheller@hellermccoy.com>
Sent: Tuesday, August 25, 2026 2:34 PM
To: Stacy Radford <sradford@montville-ct.org>
Cc: Richard Deschamps <advancedsurvey@aol.com>
Subject: Re: 26IWC11 - 38 Laurel Point Drive

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good afternoon Stacy:

The project narrative does require erosion control blankets on the fill slope. If this requirement is not also on the plan, I will have Rick add it.

The 3.5:1 slope in the narrative is a typo. The correct proposed slope is 2.5:1. I will correct.

Please note that there are no limits of clearing. The lot has been cleared for years. I will have Rick add a "limit of disturbance " note at the silt fence location. Rick will address the other comments.

Harry

Heller, Heller & McCoy
736 Norwich-New London Turnpike
Uncasville, CT 06382
Telephone: (860) 848-1248
Facsimile: (860) 848-4003