

ADDENDUM NO. 2

Notice to Bidders for

Town of Montville
Public Works Drainage Improvements
2020-5

for
Town of Montville

ADDENDUM ISSUED: May 01, 2020

This Addendum forms part of the Contract Documents and modifies the original Project Manual & Specifications and Drawings dated April, 2020. Acknowledge receipt of this Addendum in the Bid Proposal. Failure to do so may subject the Bidder to disqualification.

This Addendum is issued to modify the Contract Documents as follows:

Response to Questions

1. Please clarify the slope protection. Is “Standard Rip-Rap” an approved material for slope protection? Rip Rap would be placed with excavator to grades indicated.

Response: “Standard Rip-Rap shall not be acceptable alternative for slope protection. “Intermediate Rip-Rap” in accordance with Form 817 shall be an acceptable alternative for slope protection.

END OF ADDENDUM